

Decorative Hinged Bahama and Colonial Systems and  
Decorative Fixed Bahama, Colonial, & Shutter Panels

MICHAEL TRAPASSO  
PROFESSIONAL ENGINEER #62482

DATE: 08/04/2011

Maximum Design Pressures  
Fixed Panel, Hinged & Fixed  
Bahama & Colonial Systems  
+ 84.7 psf & - 113.3 psf  
  
Bahama Over Colonial Shutter  
+ 77 psf & - 77 psf



BRISCOE SHUTTERS INC.  
2841 Shoreview Drive  
Naples FL 34112  
www.bsishutters.com  
Office: 239-774-2025  
Fax: 239-774-9483

Patent No: US 6,996,934 B2  
US 7,131,480 B2

3609 COTTAGE CLUB LANE  
NAPLES, FLORIDA 34105

FASTENER SCHEDULE  
135 mph, EXPOSURE B & C

DRAWING NO. SHEET NO.  
FBC-135 1 of 1

**Decorative Shutter Fastener Schedule: Wind Velocity 135 mph,  
Importance Factor 1.00, Building Height 35'**

Exposure "B", 3/16" Fastener, Embed 1-1/4" Minimum into Building Structural Components								Exposure "B", 1/4" Fastener, Embed 1-1/4" Minimum into Building Structural Components							
Width of Shutter								Width of Shutter							
	2	3	4	5	6	7		2	3	4	5	6	7		
Height of Shutters	2	1	2	2	3	3	3	2	1	2	2	2	3	3	2
	3	2	2	3	4	4	5	3	2	2	3	3	4	4	3
	4	2	3	4	5	5	6	4	2	3	3	4	5	5	4
	5	3	4	5	5	6	7	5	2	3	4	5	6	6	5
	6	3	4	5	6	7	8	6	3	4	5	6	6	7	6
	7	3	5	6	7	8	10	7	3	4	5	6	7	8	7
	8	4	5	7	8	9	11	8	3	5	6	7	8	9	8
	9	4	6	7	9	10	12	9	4	5	6	8	9	10	9
	10	4	6	8	10	11	13	10	4	5	7	8	10	11	10
Height of Shutter															

Exposure "C", 3/16" Fastener, Embed 1-1/4" Minimum into Building Structural Components								Exposure "C", 1/4" Fastener, Embed 1-1/4" Minimum into Building Structural Components							
Width of Shutter								Width of Shutter							
	2	3	4	5	6	7		2	3	4	5	6	7		
Height of Shutters	2	2	2	3	4	4	5	2	2	2	3	3	4	4	2
	3	2	3	4	5	6	6	3	2	3	4	4	5	6	3
	4	3	4	5	6	7	8	4	3	4	4	5	6	7	4
	5	4	5	6	7	9	10	5	3	4	5	6	7	8	5
	6	4	6	7	9	10	11	6	4	5	6	7	9	10	6
	7	5	6	8	10	11	13	7	4	6	7	8	10	11	7
	8	5	7	9	11	13	15	8	4	6	8	9	11	13	8
	9	5	8	10	12	14	16	9	5	7	9	10	12	14	9
	10	6	8	11	13	15	18	10	5	7	9	11	13	15	10
Height of Shutters															